

BILANS CIEPLNY PODŁĄCZANYCH BUDYNKÓW

Tabela nr 1

LP	BUDYNEK	ADRES	Q _{co}	Q _{cw} u- II st.	Q went.	ΣQ	G _{co}	G _{cwu- II st.}	G went.	ΣG	ΣG - na przyłączy co
			[kW]	[kW]	[kW]	[kW]	[t/h]	[t/h]	[t/h]	[t/h]	[t/h]
1	2	3	4	5	6	7	8	9	10	11	11
1	Blok 170/171	ul. Hubala 2.	220	80	-	300,0	3,44	1,53	-	4,97	4,97
2	Blok 172 (W-1)	ul. Hubala 6.	220	120	-	340,0	3,44	2,29	-	5,73	5,73
3	Blok 172 (W-2)	ul. Hubala 6.	100	-	-	100,0	1,56	-	-	1,56	1,56
4	Blok 173 (W-1)	ul. Hubala 7.	220	160	-	380,0	3,44	3,06	-	6,50	6,50
5	Blok 173 (W-2)	ul. Hubala 7.	110	-	-	110,0	1,72	-	-	1,72	1,72
6	Blok 174	ul. Hubala 5.	110	-	-	110,0	1,72	-	-	1,72	1,72
7	Blok 175 węzeł (c.o.) i (c.o. +c.w.u.)	ul. Hubala 3.	100	-	-	100,0	1,56	-	-	1,56	4,08
			100	50	-	150,0	1,56	0,96	-	2,52	
8	Blok 176 węzeł (c.o.) i (c.o. +c.w.u.)	ul. Hubala 1	100	-	-	150,0	1,56	-	-	1,56	4,08
			100	50	-	150,0	1,56	0,96	-	2,52	
9	Blok 192 węzeł (c.o.) i (c.o. +c.w.u.)	ul. Batalionów Chłopskich 12.	100	-	-	100,0	100,0	1,56	-	1,56	4,08
			100	50	-	150,0	1,56	0,96	-	2,52	
10	Blok 193 węzeł (c.o.) i (c.o. +c.w.u.)	ul. Batalionów Chłopskich 14.	140	-	-	140,0	2,19	-	-	2,19	6,10
			140	90	-	230,0	2,19	1,72	-	3,91	

LP	BUDYNEK	ADRES	Q _{co}	Q _{cwu} - II st.	Q went.	ΣQ	G _{co}	G _{cwu} - II st.	G went.	ΣG	ΣG - na przyłączu co
11	Lodziarnia	ul. Hubala 6A.	17,4	3,5	-	20,9	0,27	0,07	-	0,34	0,34
12	Kościół	ul. Retkińska 127.	100	-	-	100	1,56	-	-	1,56	1,56
13	Plebania	ul. Retkińska 127.	117,3	17,7	-	135,0	1,83	0,34	-	2,17	2,17
14	Przychodnia	ul. Wyszyńskiego dz.316/252	163,0	27,5	-	190,5	2,55	0,53	-	3,08	3,08
							Razem			47,69	47,69